



A GREENHOUSE MEASURING 500 M² SOIL SOURCE HEAT PUMP THE COST OF THE COMMISSIONING WITH ANALYSIS AND A COAL BOILER COMPARISON WITH HEATING SYSTEM

Yavuz ŞAHİN

Energy Resources and Management Program, Advanced Technologies, Eskişehir Technical University, Eskişehir, Turkey

ABSTRACT

The biggest goal is to increase product yield and protect against natural disasters in greenhouse applications. In order to grow quality products throughout the year, it is vital not to be affected by hot or cold weather conditions. Heating is generally provided by coal boiler systems, while various methods are applied for cooling. In this article, which aims to compare the application of Ground Source Heat Pump (GSHP) as a single air conditioning system capable of heating and cooling with the other system, it is tried to explain that renewable energy can be applied in greenhouses.

Keywords: Ground Source Heat pump, Bore Hole Exchanger, Heat Pump, Greenhouse.

1. INTRODUCTION


Greenhouses have come across as a very preferred agricultural production method in recent years with many advantages. One of the biggest advantages of greenhouse cultivation is undoubtedly being able to grow crops regardless of climatic conditions. Performing cost analysis of Ground Source Heat Pump (GSHP) and Coal Boiler Heating System (CBHS) applications in a greenhouse will give us an idea so that we can see the difference between the two methods.

2. STRUCTURED FEATURES OF THE GREENHOUSE

We need to know the structural properties of the greenhouse where the application will be carried out in order to determine the heat loss and annual heat needs. After determining the heat loss and annual heat requirement, the device capacities will be determined. In light of these values, installation and operating costs will be examined.


2.1. General Dimensions and Coating Material

The width, height, length and ceiling height of the greenhouse to be built are given as follows. (Figure 1)



34
35 **Figure 1** *Greenhouse dimensions*

36 The material to be used for the greenhouse is selected as a single chamber 8mm thick polycarbonate
37 material with high thermal insulation and light permeability.



38
39 **Figure 2** *Properties of polycarbonate sheet to be used in greenhouse coating*

40 **2.2. Total Surface Area and Volume Calculations With Heat Loss**

41 Surfaces that cause heat loss; it is the side walls and ceiling of the greenhouse, where it comes into
42 contact with the outside air. When the surface area is multiplied by the heat transfer coefficient of the
43 material used in these parts, it will show us how much heat we lose on these surfaces. Therefore, we
44 will have to find the external contact surface area first for the heat loss calculation we will make in the
45 future.

46 Using the area formula

47
$$A=W*H \tag{2.1}$$

48 The parameters in this equation are as follows;

49 A = Area [m²]

50 W = Width [m]

51 H = Greenhouse Height [m]

52 The front and rear walls in the Gothic structure are each calculated as 48 m² by the drawing program. 4
53 gothic wall areas;

54
$$A=4*48=192m^2$$

55 Using the field formula for 2 side walls with external contact;

56
$$A= (26*4) *2=208 m^2$$

57 Using the field formula for 2 ceiling covers with external contact;

58
$$A= (10,21*26) *2=530,92 m^2$$

59 Total external contact surface area;

60
$$GA= Ag +Ay +At= 192 +208 +530,92= 930,92 m^2 \approx 930 m^2$$

61 If we use the volume formula to calculate the internal volume that will be required to calculate the annual
62 heat requirement;

63
$$V= Ag*Gs \tag{2.2}$$

64 The parameters in this equation are as follows;

65 V = Greenhouse volume [m³]

66 Ag = Gothic wall area [m²]

67 Gl = Greenhouse length [m]

68 Using the total volume of the greenhouse in 2 blocks, the volume formula;

69
$$V= (48*26) *2=2496 m^3$$

70 **3. CALCULATION OF HEAT LOSS AND ANNUAL HEAT REQUIREMENT**

71 **3.1.1. Heat Loss Account**

72 There is a lot of heat loss in greenhouses due to lightness and ventilation requirements to ensure light
73 permeability. Therefore, devices with high heating capacity are preferred. High heat loss also increases
74 the energy need and, of course, the energy cost.

75 The method proposed by the NSW (New South Wales Government Department of Primary Industries –
76 Agriculture) [1] will be used when calculating heat loss considering that the greenhouse is in Eskisehir
77 region. In this method, the total heat loss value is equal to the sum of transport and heat loss (QC),
78 infiltration and heat loss (QL) and radiation heat loss (QR).

79
$$QT = QC + QL + QR \tag{3.1}$$

80 The equation 3.2 will be used when calculating the total heat loss value, since the amount of heat transfer
81 with radiation is usually negligible.

82
$$QT = QC + QL \tag{3.2}$$

83 The heat loss value realized by transport is calculated in kW with the following expression.

84
$$QC = (U *SA *\Delta T) / 1000 \tag{3.3}$$

85 The parameters in this equation are as follows;

- 86 U = Total heat transfer coefficient [W/m²°C]
 87 SA = Total surface area of greenhouse cover₁ [m²]
 88 ΔT = Temperature difference, t_i – t_o [°C]
 89 t_i = Greenhouse interior design temperature [°C]
 90 t_o = Outdoor design temperature [°C]

91 The value of 3.3 W/m²°C in figure 2.2 is used to determine the total heat transfer coefficient (U) for the
 92 greenhouse. For ΔT; it was accepted that the external temperature would be 15 °C at the internal
 93 temperature of -9 °C and it was foreseen that there would be a temperature difference of 24 °C. If so, if
 94 we calculate the value of heat loss realized by transport;

95
$$QC = (3,3 * 930 * 24) / 1000 = 73,66 \text{ kW}$$

96 The amount of heat lost as a result of infiltration can be calculated in equations 3.4 to kW.

97
$$QL = (0,373 * \Delta T * V * E * W) / 1000 \tag{3.4}$$

98 The parameters in this equation are as follows;

99 Temperature difference [°C] including ΔT = t_i – t_o

100 V = Greenhouse volume [m³]

101 E = Air exchange coefficient (Table 1)

102 W = Wind factor (Table 2)

103 If we accept the Air Change Factor from Table 3.1 for the design of a single-storey polyethylene film
 104 and metal-frame greenhouse, it will be a relatively average value and a close value for the polycarbonate
 105 structure. The wind factor will be used in Eskisehir for the value corresponding to <25 km/h as the
 106 average wind speed does not exceed 25 km/h.

107

108 **Table 1** Air Exchange coefficient (E) values

GREENHOUSE DESIGN	WEATHER CHANGE FACTOR (E)
Single layer polyethylene film and metal skeleton	1,0
Double layer polyethylene film and metal skeleton	0,7
Single glass and metal skeleton	1.08

109

110 **Table 2** Wind Factor (W) value

WIND SPEED (KM/H)	WIND FACTOR (W)
<25	1,0
30	1,025
35	1,05
40	1,075

111

112 If we calculate heat loss by infiltration according to this equation (3.4);

113
$$QL = (0,373 * 24 * 2496 * 1 * 1) / 1000 = 22,34 \text{ kW}$$

114 Back to the QT equation (3.1), our total heat loss;

115
$$QT = 73,66 + 22,34 = 96 \text{ kW}$$

116 We found the total heat loss caused by transport and infiltration as 96 kW, according to this value, we
 117 can choose our heater capacity not to fall below 105.6 kW with a 10% safety share. If so, a Ground
 118 Source Heat pump (GSHP) or Coal Boiler Heating System (CBHS) that can provide 116 kW of heating
 119 and approximately 100 kW of cooling power can be selected for this greenhouse.

120 **3.1.2. Annual Heat Requirement Account**

121 Period when heating is needed for Eskisehir region; It is a 6-month period covering November-April. If
122 we calculate the total annual heat requirement from the equation of 3.5 by calculating the heat
123 requirement separately for each month;

124 $Q(\text{ay}) = U \cdot (A_c / A_g) \cdot (t_{id} - t_{st} - t_{mn}) \cdot n_n \cdot n_d$ [Wh /m² ay] (3.5)

125 U = Total heat transfer coefficient [W/m²K]

126 A_c / A_g = Greenhouse cover surface area / Greenhouse base area ratio

127 T_{id} = Greenhouse indoor design temperature [°C]

128 t_{mn} = Average night temperature value

129 t_{st} = Average value of night temperature increase due to heat stored in the ground during the day
130 [°C]

131 n_n = Number of night hours

132 n_d = Number of days heated during the month

133 The annual heat requirement is calculated according to equation 3.4 and given in table 3 below by month.

134

135 **Table 3** Year heat requirement

MONTHS	HEAT NEED (KW)
November	6.262
December	13.519
January	17.482
February	12.342
March	7.617
April	1.739
SUM	58.961

136

137 The annual heat requirement of the 500 m² polycarbonate cladding greenhouse was calculated as 58.961
138 kW from table 3.3, kg of this value. Value from Cal unit; 5,070,944 kg. Cal.


139 **4. GROUND SOURCE HEAT PUMP (GSHP) DESCRIPTION**

140 Thanks to the Drilling Heat Exchangers (BHE) placed underground by drilling, we call the devices that
141 obtain higher heat output by taking the heat drawn from the underground. The principle of operation of
142 the device is based on the carnot cycle. This cycle; it is a closed cycle in which energy remains constant,
143 cannot escape outside, works at the highest efficiency and repeats itself constantly. We see this cycle
144 in the figure below (Figure 3).


145 The sections with the most heat transfer are the sections marked with 2 and 4 in the top graph. In these
146 sections, the heat is drawn by the drilling heat exchanger according to the heating or cooling preference
147 and given to the Evaporator.

148

P : Pressure
 V : Volume
 T_H : High temperature curve
 T_L : Low temperature curve



149
 150 **Figure 3** Carnot cycle
 151



152
 153 **Figure 4** Ground Source Heat Pump Operating principle

154 For example, if you want to use in the environment, the output part should be heating (2). Heat transfer
 155 in the cooling (4) section is provided to the user through energy wells without any cost. The section
 156 shown in the graph (1) is the only part that needs electricity, where the compressor used to compress the
 157 gas works with electricity. The part shown in the graph (3) is the part where the gas expands again with

158 the help of the expansion valve after heating (2) work is done in the environment. In this section, it does
159 not cost the user. In summary; This cycle, which takes place for heating, also requires energy only to
160 compress the refrigerant (1). In other stages, the carnot cycle is completed without the need for the
161 science of consuming Electrics. GSHP, which was able to perform this cycle together with the energy
162 well, made approximately 6-8 units of heating using 1 unit of electricity (COP=6-8).

163 **5. COST ANALYSIS**

164 The cost items that we will focus on when conducting cost analysis will be investment and operating
165 (variable) cost. Keeping the air conditioning in the greenhouse stable is very important both in terms of
166 harvesting year-round and in terms of product quality. Therefore, it is right to evaluate the cost of
167 opportunity by ignoring it. By comparing the investment costs for both heating methods and the
168 operating costs for the first 10 years, it can be decided which system will be more beneficial in a long-
169 term investment such as greenhouse.

170 Unfortunately, using renewable energy is one of the methods with the highest investment costs. External
171 dependence on machine parts and rapid exchange rate increase are the biggest obstacles in this method.
172 However, renewable energy, which is low in operating costs and environmentally friendly, has proven
173 to be a long-term rush.


174 **5.1. GSHP Installation Cost**

175 **5.2. BHE Cost**

176 The most important part for GSHP is undoubtedly the earth's crust. It allows us to heat or cool using the
177 heat in the earth's crust. Coefficient Of Performance (COP) is very high on GSHP devices. One reason
178 for this is that the underground temperature is stable and not affected by seasonal changes. The other
179 reason is that heat transfer is carried out in a large mass by the ingenuity of Drilling Heat Exchangers
180 (BHE) (Figure 5). This large underground mass cannot be easily heated and cooled, and a very large
181 amount of heat, depending on the number of BHE, allows us to draw or store heat. Drilling Exchangers,
182 which account for **37%** of the GSHP investment cost, are the most important part in terms of investment
183 cost as well as GSHP performance. It must be calculated very precisely both for COP and for the cost
184 of investment. In order to find the number of BHEs, we must know the following parameters,
185 respectively.

- 186 1. Heating capacity needed (kWh)
- 187 2. Coefficient of Performance (COP) of GSHP device
- 188 3. Borehole Heat Exchanger Specific Heat Drawing Capacity (W/m)

189



190
191 **Figure 5** Section Of Bore Hole Exchanger

192
193 Heating capacity from these parameters; In the first sections it was calculated as 96 kWh, together with
194 a 10% safety share, we will accept 105 kWh for the amount of BHE. Most of the heating needs will be
195 withdrawn from the underground by GSHP and this amount will be calculated according to Coefficient
196 of Performance. COP in Heat Pumps; The ratio of heating capacity to energy consumed. Cop 6-8 range
197 for GSHP devices. The COP ratio for GSHP to be used for this greenhouse will be 6. Accordingly,
198 GSHP will consume 1/6 of this electricity while generating 105 kWh of heat. Accordingly;

199
$$105 \text{ kWh} / 6 = 17,5 \text{ kWh}$$

200 If so, GSHP will consume 17.5 kWh of electrical energy per hour during its maximum capacity and will
201 be able to provide 105 kWh of heating in the greenhouse by drawing 87.5 kWh of heat from the
202 underground. How much BHE does it take to draw 87.5 kWh of heat from the ground? To answer this
203 question, we need to find the specific heat-drawing capacity of bhe one meter long. In fact, in order to
204 determine this value precisely, a guide BHE should be placed in the area where the greenhouse will be
205 built and a thermal response test should be performed. This is essential for an air conditioning of this

206 capacity, especially for an investment with high costs. This test is not carried out because GSHP
 207 application is almost nonexistent in our country. Therefore, this selection is made from the following
 208 table (table 4) in accordance with the ground structure.
 209

210 **Table 4** Specific heat drawing capacities according to ground structure (W/m)

UNDERGROUND STRUCTURE	SPECIAL HEAT DRAW CAPACITY
DRY, SANDY	20-40 W/m
WET, ROCK	50-60 W/m
GROUNDWATER FOUND	70-90 W/m

211
 212 Since it is known that there is groundwater close to the surface in the area to be built in the greenhouse,
 213 a value of 80 W/m, which is between **70-90 W/m**, can be used. If so;

$$214 \quad 87,5 \text{ kWh} * 1000 = 87500 \text{ W} / 80 = 1093,75 \text{ m BHE}$$

215 A total of 8 wells, each 150 m long, 7 pieces and 100 m long one, will be drilled and placing 1100 m
 216 BHE in these wells will be enough for the greenhouse. Drilling service, piping cost, injection and labor
 217 total meter price is obtained from the market as 200 TL/m +VAT (20€). Accordingly, our total BHE
 218 cost;

$$219 \quad 1100 * 200 = \underline{220.000,00 \text{ TL}}$$

220 **5.3. GSHP device cost**

221 Although GSHP has a lot of applications in the world, unfortunately it is not very well known in our
 222 country. For this reason, manufacturers have developed their policies in Turkey mainly to sell AirBorne
 223 Heat Pumps. Therefore, although this is not his main job, there are very few manufacturers who can
 224 produce as special orders on demand. This, of course, increases the cost of the device. The manufacture
 225 of a device with 105 kWh heating and 86 kWh cooling power costs approximately 176,000,00 TL +VAT
 226 (17,600€).

227 **5.4. Fan Coil cost to be used in greenhouse**

228 One of the biggest advantages of TKIP is that the device can be used in heating and cooling mode.
 229 Therefore, devices similar to the air conditioning unit will be placed in the greenhouse. Hot water will
 230 be sent to these internal units (Fan Coil) in the range of 35-40°C in heating mode and cold water in the
 231 range of 5-10°C in cooling mode. In heating or cooling mode, it will be enough to use 7 of these internal
 232 units that can provide the desired temperature homogeneously in the greenhouse for 500 m² greenhouse
 233 area. Total cost of internal units with a unit price of 9,000,00 TL +VAT (900€);

$$234 \quad 7 * 9.000 = \underline{63.000,00 \text{ TL}}$$

235 **5.5. Installation elements and assembly workmanship costs**

236 The cost of installation elements and assembly workmanship is given in the following table (table 5) in
 237 a list.
 238

239 **Table 5** Installation and labor costs

COST ITEM	Amount	P. Price	Sum
Circulation Pump (25 m ³ /h)	2 adet	750 €	1500 €
Expansion Tank	2 adet	300 €	600 €
Battery Tank 1000 LT	1 adet	950 €	950 €
The connection is and collectors	1 adet	3000 €	3000 €

Labor	1 adet	2250 €	2250 €
SUM			8300 €

240

241 Since the current exchange rate of euro/TL is 10 TL, the total cost is 83.000.00 TL.

242

243 5.6. Mold and concrete costs

244 It is important to include BHE and the pipeline from there to the boiler room in a concrete canal, both
 245 to use the upper area and to isolate these sections. Therefore, it is right to take into account the cost of a
 246 concrete canal as seen in the Figure (Figure 6).



247

248 **Figure 5** BHE concrete canal application

249 Total 40 m² mold workmanship and 10 m³ c25 concrete cost in concrete channel application for eight
 250 BHE;

251
$$(40 \text{ m}^2 * 50 \text{ TL}) + (10 \text{ m}^3 * 250 \text{ TL}) = 5500,00\text{TL}$$

252

253 **Table 6** GSHP Sum investment cost

COST ITEM	AMOUNT
BHE Cost	220.000,00 TL
GSHP Device Cost	176.000,00 TL
Fan Coil Cost	63,000,00 TL
Installation Elements and Labor cost	83.000,00 TL

Mold Concrete Cost for Canal	5.500,00 TL
TOTAL COST	547.500,00 TL

254
255
256
257
258

5.7. Coal Boiler Cost

A coal boiler with a capacity of 116 kWh is easily available from the market. The average quality device will cost approximately 14,200.00 TL (1420 €).

Table 7 *Installation and labor costs*

COST ITEM	AMOUNT	PRICE	SUM
Circulation Pump (Wilo 25 m³/h)	1 piece	750 €	750 €
Expansion Tank	1 piece	500 €	500 €
48 mm iron pipe	1200 m	1.81 €	2172 €
The connection is the goods. And collectors	1 piece	2000 €	2000 €
Labor	1 piece	2250 €	2.250 €
SUM			4250 €

259
260
261
262
263
264
265
266
267

Iron pipes, which are used as heat transmission devices in greenhouses, are the most commonly used method. In this method, heating is provided by circulating the water heated by the coal boiler in the 48 mm thick iron pipes laid on the floor of the greenhouse with a certain frequency. When 70 °C of water is circulated in these pipes, approximately 96 Wh heat is transferred from each 1 m pipe. In so, into the greenhouse; It is necessary to lay $105000W/96 = 1093$ m pipe. This amount can be determined as 1200 m taking into account the device capacity and the distance between the boiler greenhouse.

Table 8 *Total investment cost of coal boiler*


COST ITEM	AMOUNT
116 kWh Coal Boiler	14.200.00 TL
Plumbing and the cost of labor	42,500,00 TL
TOTAL COST	56,700,00 TL

268
269
270
271
272
273
274
275

5.8. GSHP Operating Cost

Energy consumption will be the most important expense item in GSHP operating cost. When calculating this consumption, the annual heat requirement and the COP value of the GSHP device are used. The annual heat requirement calculated in previous sections is 58,961 kW (5,070,944 kg). Cal) (Table 3) can be found using an annual consumption COP (6) value. Annual electricity consumption as GSHP will meet 1/6 of the heat needed by the greenhouse from the electricity grid;

$$58.961 \text{ kW}/6 = 9827 \text{ kW year}$$




276
277 **Figure 6** GSHP heat requirement diagram

278 In the light of these data, the operating cost of the investment for the first 10 years is seen in table 9. The
279 increase in the price of electricity consumption when creating the table was accepted as 10% annually.

280 **Table 9** GSHP 10-year energy consumption price

	CONSUMPTION (Kw)	UNIT PRICE (TL)	AMOUNT (TL)
2020	9827	0,60	5.914,77
2021	9827	0,66	6.506,25
2022	9827	0,73	7.156,88
2023	9827	0,80	7.872,56
2024	9827	0,88	8.659,82
2025	9827	0,97	9.525,80
2026	9827	1,07	10.478,38
2027	9827	1,17	11.526,22
2028	9827	1,29	12.678,84
2029	9827	1,42	13.946,73
		SUM	94.266,25



281
282 **Graphic 1.** GSHP 10-year energy consumption price

283 GSHP devices and Fan Coils do not need periodic maintenance. They do not fail easily because they
 284 provide electronic control within themselves. If there's a problem with the mains or water lines, it
 285 protects itself. Thanks to its software that can provide remote access, there is no need to keep it under
 286 surveillance. Since it does not produce solid waste, there is no waste disposal problem. Naturally, there
 287 is no need for additional employment for this job. There is no risk of explosion or fire. Therefore, it is
 288 exempt from many regulations and the burdens stipulated by these regulations. Since there is no CO₂
 289 oscillation, there is no filter or chimney cost. For these reasons, the operating cost can be considered
 290 limited only to electricity consumption.

291 **5.9. Coal Boiler Operating Cost**

292 When examining the cost of operating a coal boiler, it will be required to employ a staff member who
 293 will take care of the boiler system, except for the annual coal consumption cost. These personnel must
 294 be skilled personnel who are trained to burn the boiler. These personnel will have to do things like
 295 feeding coal according to the coal needs of the boiler, monitoring boiler pressures for safety, cleaning
 296 the boiler and throwing the ash out. If we examine these two cost items.


297 **5.10. Annual coal consumption cost**

298 Annual coal consumption will be determined according to the annual heat requirement. In order to make
 299 this calculation, it is necessary to know the thermal value of the coal to be used and the price of tons.
 300 Heat value 7500 kg. The ton price of imported coal, which is Cal, is 1300,00 TL +VAT on the market.
 301 According to these values, the first 10 years of coal costs are given in table 10. The increase in the price
 302 of imported coal was accepted as 10% per year when the table was created.

303

304 **Table 10** 10-year energy consumption cost for Coal Boiler

year	CONSUMPTION (kg)	UNIT PRICE (TL/kg)	AMOUNT (TL)
2020	10.400	1,30	13.520,00
2021	10.400	1,43	14.872,00
2022	10.400	1,57	16.359,20
2023	10.400	1,73	17.995,12
2024	10.400	1,90	19.794,63
2025	10.400	2,09	21.774,10
2026	10.400	2,30	23.951,50
2027	10.400	2,53	26.346,66
2028	10.400	2,79	28.981,32
2029	10.400	3,07	31.879,45
		SUM	215.473,98



305

306 **Graphic 2** Kömür kazanı için 10 yıllık enerji tüketim maliyeti

307 **5.11. Annual Labor Cost**

308 The 6-month employer cost of the personnel who will ship and manage the boiler room, ensure that the
 309 coal burns well and empty and dispose of solid waste is 23.407.82 TL (table 11).
 310


311 **Table 11** 6 months cost of a single worker to the business

Gross to Nete Salary Account												
	gross	SSK Worker	Unemployment Worker	Monthly Income Tax	Stamp Duty	Cumulative Tax Base	Net	Minimum Livelihood Discount	Total Seized	SSK Employer	Unemployment Employer	Total Cost
January	2943,00	412,02	29,43	375,23	22,34	2501,55	2103,98	220,73	2324,71	456,16	58,86	3458,03
February	2943,00	412,02	29,43	375,23	22,34	5003,10	2103,98	220,73	2324,71	456,16	58,86	3458,03
Mart	2943,00	412,02	29,43	375,24	22,34	7504,65	2103,98	220,73	2324,71	456,16	58,86	3458,03
April	2943,00	412,02	29,43	375,23	22,34	10006,20	2103,98	220,73	2324,71	456,16	58,86	3458,03
November	2943,00	412,02	29,43	500,31	22,34	27517,05	1978,90	220,73	2199,63	456,16	58,86	3458,03
December	2943,00	412,02	29,43	500,31	22,34	30018,60	1978,90	220,73	2199,63	456,16	58,86	3458,03
sum	35316,00	4944,24	353,16	4903,71	268,08	30018,60	24846,83	2648,76	27495,59	5473,92	706,32	20748,18

312
 313 A worker's weekly working time is legally 45 hours and it is mandatory by labor law to use a week's
 314 holiday. Within this information, it is necessary to have a worker for the boiler room during the night
 315 periods, legally and in order to maintain product quality. The employer cost of a job for 6 months was
 316 TL 20,748.18, which is TL 41,496.36 for 2 workers. The right to eat 1 meal per day will be 20*2=40
 317 TL for both workers, which is 40*30=1200 TL per month. To include monthly IAS expenses and OHS
 318 costs, this figure will be 6*1500=9000 TL annually. As a result, our annual labor cost for dispatching
 319 and managing the boiler room in the greenhouse; 41.496.36+9.000.00= 50.496.36TL. 10-year cost with
 320 10% CPI per year given at table 12.

321
 322 **Table 12** 10 years of labor costs for coal boiler room dispatch and administration

YEAR	LABOR COSTS (TL)
2020	50.496,36
2021	55.546,00
2022	61.100,60
2023	67.210,66
2024	73.931,72
2025	81.324,89
2026	89.457,38
2027	98.403,12
2028	108.243,43
2029	119.067,78
SUM	804.781,93




323
324 **Graphic 3** 10 years of labor costs for coal boiler room dispatch and administration

325 It will of course be possible with a coal boiler to keep the greenhouse at the desired temperature, but it
 326 is also obvious that cooling cannot be done. Therefore, product continuity will not be provided for 365
 327 days, which will negatively affect the cost of operating the greenhouse as it will reduce the product
 328 quality and continuity of the greenhouse. If we ignore such indirect effects and cooling costs that may
 329 occur as a result of the operations that can be done to cool the greenhouse, the 10-year operating cost of
 330 the greenhouse will be like table 13.

331
332 **Table 13** 10-year operating cost for coal boiler

YEAR	FUEL COST (TL)	LABOR COST (TL)	TOTAL OPT. COST3
2020	13.520,00	50.496,36	64.016,36
2021	14.872,00	55.546,00	70.418,00
2022	16.359,20	61.100,60	77.459,80
2023	17.995,12	67.210,66	85.205,78
2024	19.794,63	73.931,72	93.726,35
2025	21.774,10	81.324,89	103.098,99
2026	23.951,50	89.457,38	113.408,89
2027	26.346,66	98.403,12	124.749,78
2028	28.981,32	108.243,43	137.224,75
2029	31.879,45	119.067,78	150.947,23
SUM	215.473,98	804.781,93	1.020.255,91



333
334 **Graphic 4** 10-year operating cost for coal boiler

335 **5.12. Comparison Of Costs**

336 Investment and operating costs were calculated in detail in both systems to make a healthy comparison.
 337 It would be very accurate to analyze cumulative costs for both methods by examining and comparing
 338 the investment cost and 10-year operating cost separately.


339 **5.13. GSHP Investment and 10 Year Operating Cost**

340 We can see the investment and 10-year operating cost of the GSHP system cumulatively in table 14
 341 from the first year of the investment.

342

343 **Table 14** GSHP cumulative cost for the first 10 years

year	INVESTMENT M.	Business MAL.	cumulative
2020	547.500,00	5.914,77	553.414,77
2021		6.506,25	559.921,02
2022		7.156,88	567.077,90
2023		7.872,56	574.950,46
2024		8.659,82	583.610,28
2025		9.525,80	593.136,08
2026		10.478,38	603.614,46
2027		11.526,22	615.140,68
2028		12.678,84	627.819,52
2029		13.946,73	641.766,25



344

345 **Graphic 5** GSHP cumulative cost for the first 10 years

346 The operating cost of the GSHP system for the first 10 years corresponds to 17% of the initial investment
 347 cost. The cumulative cost curve in Graphic 5 starts at a high value in the first year with the effect of
 348 investment cost, but follows a horizontal course in subsequent years.

349 **5.14. Coal Boiler Investment And 10 Year Operating Cost**


350 We can see the investment and 10-year operating cost of the coal boiler system cumulatively in table 15
 351 from the first year of the investment.

352

353 **Table 15** Coal boiler cumulative cost for the first 10 years

YEAR	INVESTMENTS	OPERATING COST	CUMULATIVE
2020	56.700,00	64.016,36	120.716,36
2021		70.418,00	191.134,36

2022	77.459,80	268.594,15
2023	85.205,78	353.799,93
2024	93.726,35	447.526,28
2025	103.098,99	550.625,27
2026	113.408,89	664.034,15
2027	124.749,78	788.783,93
2028	137.224,75	926.008,68
2029	150.947,23	1.076.955,91



354
355 **Graphic 6** Coal boiler cumulative cost for the first 10 years

356 The 10-year operating cost of the coal boiler system corresponds to 18 times the initial investment cost.
357 The cumulative cost curve in the Graphic (Graphic 6) starts at a low value in the first year but is
358 aggressive in subsequent years.

359 **5.15. Comparison of Costs**

360 According to graphic 7, the cumulative costs of the two systems appear to have intersected in year 6.
361 GSHP air conditioning system has transferred the enterprise to a profit of TL 435,189.66 after 10 years.
362 (Table 16)

363
364 **Table 16** Comparison of cumulative costs of GSHP and Coal Boiler for the first 10 years

YEAR	GSHP CUMULATIVE	CBHS CUMULATIVE	DIFFERENCE
2020	553.414,77	120.716,36	-432.698,41
2021	559.921,02	191.134,36	-368.786,67
2022	567.077,90	268.594,15	-298.483,75
2023	574.950,46	353.799,93	-221.150,53
2024	583.610,28	447.526,28	-136.084,00
2025	593.136,08	550.625,27	-42.510,81
2026	603.614,46	664.034,15	60.419,69
2027	615.140,68	788.783,93	173.643,25
2028	627.819,52	926.008,68	298.189,16
2029	641.766,25	1.076.955,91	435.189,66



366

367

Graphic 7 Comparison of GSHP and CBHS cumulative costs for the first 10 years

368

6. CONCLUSION

369

370

371

372

373

374

375

376

377

378

379

380

381

382

383

384

385

REFERANCES

386

387

[1] Şehmus ATAKUL (Agricultural Engineer), Determination of the use of renewable energy sources in Diyarbakir province greenhouses with energy simulation technique, 2014.